



TEST REPORT NO. 96003

Place and date of issue: Azzano X°, 9 February 1996

Client: BALEXCO - Baharain Aluminium Extrusion Company B.S.C.C.

Series tested: functional check of the "SLIDING 100" series produced by BALEXCO

Objective of test: Twin sliding window with angular joining at 45°

Test to be carried out as per French NF P 20.501 standards:

Testing of AIR SEAL
Testing of the WATER SEAL
Testing of WIND RESISTANCE

RESULTS:

CLASSIFICATION OF THE WINDOW FRAME BASED ON AIR SEAL, WATER SEAL AND WIND RESISTANCE

Based on the test results obtained, the window frame tested can be classified in the following quality classes:

• Air seal **A3**
• Water seal **E2**
• Wind resistance **V2**

(1) Values: Not classifiable / A1 / A2 / A3
(2) Values: Not classifiable / E1 / E2 / E3 / E4
(3) Values: Not classifiable / V1 / V1a / V2 / V2a / V3

**Project manager
product test & certification**

Dott. A. Cesari

General Manager

Ing. A. Negroni

SYNCR0 s.r.l. CONSULTING & ENGINEERING

40054 BUDRIO (Bologna - Italia) - Via Tubertini, 1 - Tel.(39)-51-6930270 - Fax (39)-51-6924042

Sede legale - 40121 BOLOGNA - Via Galliera, 34 - P.IVA e C.F. 04075030371





TEST REPORT NO. 96004

Place and date of issue: Azzano X°, 9 February 1996

Client: BALEXCO - Baharain Aluminium Extrusion Company B.S.C.C.

Series tested: functional check of the "SLIDING 100" series produced by BALEXCO

Objective of test: Twin sliding door with angular joining at 90°

Test to be carried out as per French NF P 20.501 standards:

Testing of AIR SEAL
Testing of the WATER SEAL
Testing of WIND RESISTANCE

RESULTS:

CLASSIFICATION OF THE WINDOW FRAME BASED ON AIR SEAL, WATER SEAL AND WIND RESISTANCE

Based on the test results obtained, the window frame tested can be classified in the following quality classes:

· Air seal	A3
· Water seal	E2
· Wind resistance	V2

(1)	Values:	Not classifiable / A1 / A2 / A3
(2)	Values:	Not classifiable / E1 / E2 / E3 / E4
(3)	Values:	Not classifiable / V1 / V1a / V2 / V2a / V3

Project manager
product test & certification

Dott. A. Cesari

General Manager

Ing. A. Negroni

SYNCRO s.r.l. CONSULTING & ENGINEERING
40054 BUDRIO (Bologna - Italia) - Via Tubertini, 1 - Tel.(39)-51-6930270 - Fax (39)-51-6924042
Sede legale - 40121 BOLOGNA - Via Galliera, 34 - P.IVA e C.F. 04075030371

